

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-248 / Long Branch BOE - AA Anastasia

Customer PO: 041155
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 13:24

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 - AAA-WC-GYM-1/Gym Lims Reference ID: AD17709-01 Matrix: Drinking Water Sampled: 04/16/25 09:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 - AAA-WC-GHL-2/Gym Hall Lims Reference ID: AD17709-02 Matrix: Drinking Water Sampled: 04/16/25 09:42:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 - AAA-DW-GYM2-3/Gym Lims Reference ID: AD17709-03 Matrix: Drinking Water Sampled: 04/16/25 09:43:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 - AAA-WC-APR-4/Auditoria Lims Reference ID: AD17709-04 Matrix: Drinking Water Sampled: 04/16/25 09:44:00									
Metals									
Lead	1.34		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 - AAA-FP-KIT-5/Kitchen Lims Reference ID: AD17709-05 Matrix: Drinking Water Sampled: 04/16/25 09:46:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5A - AAA-S-TS-5A/Teachers Room Lims Reference ID: AD17709-06 Matrix: Drinking Water Sampled: 04/16/25 09:48:00									
Metals									
Lead	1.34		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 - AAA-DW-111A-6/Room 111 Lims Reference ID: AD17709-07 Matrix: Drinking Water Sampled: 04/16/25 09:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7 - AAA-DW-111B-7/Room 111 Lims Reference ID: AD17709-08 Matrix: Drinking Water Sampled: 04/16/25 09:51:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7A - AAA-WC-HLWY1-7A/Hallway Lims Reference ID: AD17709-09 Matrix: Drinking Water Sampled: 04/16/25 09:52:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:27	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-248 / Long Branch BOE - AA Anastasia

Customer PO: 041155
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 13:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 8 - AAA-DW-112A-8/Room 112 Lims Reference ID: AD17709-10 Matrix: Drinking Water Sampled: 04/16/25 09:53:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 10 - AAA-DW-113A-10/Room 113 Lims Reference ID: AD17709-11 Matrix: Drinking Water Sampled: 04/16/25 09:54:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11 - AAA-DW-113B-11/Room 113 Lims Reference ID: AD17709-12 Matrix: Drinking Water Sampled: 04/16/25 09:55:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12 - AAA-DW-114A-12/Room 114 Lims Reference ID: AD17709-13 Matrix: Drinking Water Sampled: 04/16/25 09:56:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13 - AAA-DW-114B-13/Room 114 Lims Reference ID: AD17709-14 Matrix: Drinking Water Sampled: 04/16/25 09:57:00									
Metals									
Lead	198	D	5	5.00	µg/L	04/28/25 13:23	04/29/25 17:54	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 14 - AAA-DW-115A-14/Room 115 Lims Reference ID: AD17709-15 Matrix: Drinking Water Sampled: 04/16/25 09:59:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15 - AAA-DW-115B-15/Room 115 Lims Reference ID: AD17709-16 Matrix: Drinking Water Sampled: 04/16/25 09:59:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16 - AAA-DW-116A-16/Room 116 Lims Reference ID: AD17709-17 Matrix: Drinking Water Sampled: 04/16/25 10:01:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17 - AAA-DW-116B-17/Room 116 Lims Reference ID: AD17709-18 Matrix: Drinking Water Sampled: 04/16/25 10:01:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:50	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-248 / Long Branch BOE - AA Anastasia

Customer PO: 041155
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 13:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 18 - AAA-WC-HL1-18/Hall Lims Reference ID: AD17709-19 Matrix: Drinking Water Sampled: 04/16/25 10:02:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 20 - AAA-DW-120B-20/Room 120 Lims Reference ID: AD17709-20 Matrix: Drinking Water Sampled: 04/16/25 10:04:00									
Metals									
Lead	1.29		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21 - AAA-DW-119A-21/Room 119 Lims Reference ID: AD17709-21 Matrix: Drinking Water Sampled: 04/16/25 10:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:11	04/28/25 14:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22 - AAA-DW-119B-22/Room 119 Lims Reference ID: AD17709-22 Matrix: Drinking Water Sampled: 04/16/25 10:06:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23 - AAA-DW-122A-23/Room 122 Lims Reference ID: AD17709-23 Matrix: Drinking Water Sampled: 04/16/25 10:08:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 24 - AAA-DW-122B-24/Room 122 Lims Reference ID: AD17709-24 Matrix: Drinking Water Sampled: 04/16/25 10:09:00									
Metals									
Lead	5.73		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 25 - AAA-DW-121A-25/Room 121 Lims Reference ID: AD17709-25 Matrix: Drinking Water Sampled: 04/16/25 10:10:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26 - AAA-DW-121B-26/Room 121 Lims Reference ID: AD17709-26 Matrix: Drinking Water Sampled: 04/16/25 10:12:00									
Metals									
Lead	259	D	5	5.00	µg/L	04/25/25 12:12	04/28/25 16:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27 - AAA-DW-124-27/Room 124 Lims Reference ID: AD17709-27 Matrix: Drinking Water Sampled: 04/16/25 10:13:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:25	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-248 / Long Branch BOE - AA Anastasia

Customer PO: 041155
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 13:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 28 - AAA-DW-123-28/Room 123 Lims Reference ID: AD17709-28 Matrix: Drinking Water Sampled: 04/16/25 10:14:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29 - AAA-WC-MNHL1-29/Main Hall Lims Reference ID: AD17709-29 Matrix: Drinking Water Sampled: 04/16/25 10:15:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 30 - AAA-WC-MNHL2-30/Main Hall Lims Reference ID: AD17709-30 Matrix: Drinking Water Sampled: 04/16/25 10:16:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 30A - AAA-WC-Media-30A/Media Center Lims Reference ID: AD17709-31 Matrix: Drinking Water Sampled: 04/16/25 10:18:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 31 - AAA-NS-NRSOFF1-31/Nurse Office Lims Reference ID: AD17709-32 Matrix: Drinking Water Sampled: 04/16/25 10:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 32 - AAA-NS-NRSOFF2-32/Nurse Office Lims Reference ID: AD17709-33 Matrix: Drinking Water Sampled: 04/16/25 10:21:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 33 - AAA-DW-212-33/Room 212 Lims Reference ID: AD17709-34 Matrix: Drinking Water Sampled: 04/16/25 10:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 34 - AAA-DW-210-34/Room 210 Lims Reference ID: AD17709-35 Matrix: Drinking Water Sampled: 04/16/25 10:23:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 35 - AAA-WC-HLWY2-35/Hallway Lims Reference ID: AD17709-36 Matrix: Drinking Water Sampled: 04/16/25 10:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:50	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-248 / Long Branch BOE - AA Anastasia

Customer PO: 041155
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 13:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 36 - AAA-DW-214-36/Room 214 Lims Reference ID: AD17709-37 Matrix: Drinking Water Sampled: 04/16/25 10:27:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 37 - AAA-DW-213-37/Room 213 Lims Reference ID: AD17709-38 Matrix: Drinking Water Sampled: 04/16/25 10:28:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 38 - AAA-DW-216-38/Room 216 Lims Reference ID: AD17709-39 Matrix: Drinking Water Sampled: 04/16/25 10:29:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 39 - AAA-DW-215-39/Room 215 Lims Reference ID: AD17709-40 Matrix: Drinking Water Sampled: 04/16/25 10:31:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 15:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 40 - AAA-WC-HLWY2A-40/Hallway Lims Reference ID: AD17709-41 Matrix: Drinking Water Sampled: 04/16/25 10:33:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:12	04/28/25 16:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 41 - AAA-DW-220-41/Room 220 Lims Reference ID: AD17709-42 Matrix: Drinking Water Sampled: 04/16/25 10:35:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 16:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 42 - AAA-DW-219-42/Room 219 Lims Reference ID: AD17709-43 Matrix: Drinking Water Sampled: 04/16/25 10:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 16:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 43 - AAA-DW-222-43/Room 222 Lims Reference ID: AD17709-44 Matrix: Drinking Water Sampled: 04/16/25 10:37:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 16:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44 - AAA-DW-221-44/Room 221 Lims Reference ID: AD17709-45 Matrix: Drinking Water Sampled: 04/16/25 10:39:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 16:47	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-248 / Long Branch BOE - AA Anastasia

Customer PO: 041155
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 13:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 45 - AAA-DW-224-45/Room 224 Lims Reference ID: AD17709-46 Matrix: Drinking Water Sampled: 04/16/25 10:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 16:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 46 - AAA-DW-223-46/Room 223 Lims Reference ID: AD17709-47 Matrix: Drinking Water Sampled: 04/16/25 10:41:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 16:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47 - AAA - TS-STF2-47/Teachers Room Lims Reference ID: AD17709-48 Matrix: Drinking Water Sampled: 04/16/25 10:42:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 16:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 48 - AAA-WC-HLWY-48/Hallway Lims Reference ID: AD17709-49 Matrix: Drinking Water Sampled: 04/16/25 10:44:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 16:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 49 - AAA-DW-310-49/Room 310 Lims Reference ID: AD17709-50 Matrix: Drinking Water Sampled: 04/16/25 10:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 50 - AAA-DW-312-50/Room 312 Lims Reference ID: AD17709-51 Matrix: Drinking Water Sampled: 04/16/25 10:46:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 51 - AAA-DW-314-51/Room 314 Lims Reference ID: AD17709-52 Matrix: Drinking Water Sampled: 04/16/25 10:47:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 52 - AAA-DW-313-52/Room 313 Lims Reference ID: AD17709-53 Matrix: Drinking Water Sampled: 04/16/25 10:49:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 53 - AAADW-316-53/Room 316 Lims Reference ID: AD17709-54 Matrix: Drinking Water Sampled: 04/16/25 10:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:12	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-248 / Long Branch BOE - AA Anastasia

Customer PO: 041155
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 13:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 54 - AAA-DW-315-54/Room 315 Lims Reference ID: AD17709-55 Matrix: Drinking Water Sampled: 04/16/25 10:52:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 55 - AAA-WC-HLWY3A-55/Hallway Lims Reference ID: AD17709-56 Matrix: Drinking Water Sampled: 04/16/25 10:53:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 56 - AAA-DW-319-56/Room 319 Lims Reference ID: AD17709-57 Matrix: Drinking Water Sampled: 04/16/25 10:55:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 57 - AAA-DW-320-57/Room 320 Lims Reference ID: AD17709-58 Matrix: Drinking Water Sampled: 04/16/25 10:56:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58 - AAA-DW-321-58/Room 321 Lims Reference ID: AD17709-59 Matrix: Drinking Water Sampled: 04/16/25 10:57:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 59 - AAA-DW-322-59/Room 322 Lims Reference ID: AD17709-60 Matrix: Drinking Water Sampled: 04/16/25 10:58:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 60 - AAA-DW-323-60/Room 323 Lims Reference ID: AD17709-61 Matrix: Drinking Water Sampled: 04/16/25 11:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:14	04/28/25 17:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 61 - AAA-DW-324-61/Room 324 Lims Reference ID: AD17709-62 Matrix: Drinking Water Sampled: 04/16/25 11:02:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:04	04/28/25 17:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 62 - AAA-TS-STF3-62/3rd Floor Storage Lims Reference ID: AD17709-63 Matrix: Drinking Water Sampled: 04/16/25 11:04:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:04	04/28/25 17:26	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-248 / Long Branch BOE - AA Anastasia

Customer PO: 041155
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 13:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 63 - AAA-APR-BF-4A/All Purpose Room Lims Reference ID: AD17709-64 Matrix: Drinking Water Sampled: 04/16/25 11:06:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:04	04/28/25 17:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 64 - AAA-FP-Kit-5A/Kitchen Lims Reference ID: AD17709-65 Matrix: Drinking Water Sampled: 04/16/25 11:08:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:04	04/28/25 17:29	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 25-248 / Long Branch BOE - AA Anastasia

Customer PO: 041155
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 13:24

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517709
LIMS Reference ID: AD17709
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

25-248 / Long Branch BOE - AA Anastasia

Customer PO:

041155

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/17/2025 09:00

Reported:

05/01/2025 13:24

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

AD17709

Customer Information	Customer ID:		Billing Information	Billing ID:	
	Company Name:	TTI Environmental, Inc		Company Name:	Same
	Contact Name:	Tim Popp		Billing Contact:	
	Street Address:	1253 N Church St		Street Address:	
	City, State, Zip:	Moorestown, NJ 08054		City, State, Zip:	
	Country:	US		Country:	
Phone:	856-840-8800	Phone:			
Email(s) for Report:	nater@ttienv.com	Email(s) for Invoice:			

Project Name/No:	25-248/Long Branch BOE - AA Anastasia	Purchase Order:	041155
------------------	---------------------------------------	-----------------	--------

EMSL LIMS Project ID: (If applicable, EMSL will provide)	US State where samples collected:	State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
---	-----------------------------------	---

Samples for Compliance? ☒ Yes ☐ No	If Yes, for NPDES? ☐ Yes ☒ No	Other (Specify)	PWS ID:	State Reporting Required? ☐ Yes ☐ No
---	--	-----------------	---------	--

Samples Collected by (Check One): ☐ EMSL ☒ CLIENT	Samples Received Chilled? ☐ Yes ☐ No	Sample(s) Temperature Upon Receipt (LAB ONLY)
--	--	---

Sampled By Name: Adam Fisher	Sampled By Signature: Adam Fisher	No. of Samples in Shipment: 65
------------------------------	-----------------------------------	--------------------------------

Turn-Around-Time (TAT)	Standard Turn-Around-Time: ☒ 2 Weeks	The following TAT's are subject to Lab approval. Call lab to confirm TAT before submittal:	☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day
------------------------	--	--	--

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix	Preservative	List Test(s) Needed (Write in test below, then check on sample line:)								Comments		
				DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	1 HCL 2 HNO3 3 H2SO4 4 ICE 5 Other Describe below in Special Instructions	Test 1: Lead	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:			
See attached		☒		DW	2 HNO3	☒										Needs preservative

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Needs HNO3

Reporting Requirements:	☒ Results Only	☐ Results and QC	☐ Reduced Deliverables	☐ Hresults EDD	☒ Excel	☐ Other (Describe Above)
-------------------------	--	---	---	---------------------------------------	---	---

Method of Shipment:	Sample Condition Upon Receipt:	Received on Ice? Check if Yes: ☐
---------------------	--------------------------------	---

Relinquished by: Adam F.	Date/Time: 4/16/25 3:00	Received by: [Signature]	Date/Time: 4/17/25 09:00
--------------------------	-------------------------	--------------------------	--------------------------

Relinquished by:	Date/Time:	Received by:	Date/Time:
------------------	------------	--------------	------------

Controlled Document - COC-07 Chemistry R13 05/31/2024

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD17709

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-248		CLIENT: Long Branch BOE		FACILITY: Amerigo A. Anastasia School			
PO #: 041155		SAMPLER(S): <i>Adam F.</i>		DATE: <i>4/16/25</i>		ADDRESS: 92 7th Ave, Long Branch, NJ 07740	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
0	AAA-FRDMF-0L-0		Initial	Point of Entry	250mL	Location not provided, confirm while on site.	
1	AAA-WC-GYM1-1	GYM	9:40	Initial	Water Cooler	250mL	
2	AAA-WC-GHL-2	Gym Hall	9:48	Initial	Water Cooler	250mL	
3	AAA-DW-GYM2-3	GYM	9:43	Initial	Bubbler	250mL	
4	AAA-WC-APR-4	Auditoria	9:44	Initial	Water Cooler	250mL	
5	AAA-FP-KIT-5	Kitchen	9:46	Initial	Food Prep	250mL	
5A	AAA-S-TS-5A	Teachers Room	9:48	Initial	Sink	250mL	
6	AAA-DW-111A-6	Room 111	9:50	Initial	Bubbler	250mL	
7	AAA-DW-111B-7	Room 111	9:51	Initial	Bubbler	250mL	
7A	AAA-WC-HLWY1-7A	Hallway	9:52	Initial	Water Cooler	250mL	
8	AAA-DW-112A-8	Room 112	9:53	Initial	Bubbler	250mL	
9	AAA-DW-112B-9	Room 112	Initial	Bubbler	250mL	PNE	
10	AAA-DW-113A-10	Room 113	9:54	Initial	Bubbler	250mL	
11	AAA-DW-113B-11	Room 113	9:55	Initial	Bubbler	250mL	
12	AAA-DW-114A-12	Room 114	9:56	Initial	Bubbler	250mL	
13	AAA-DW-114B-13	Room 114	9:57	Initial	Bubbler	250mL	
14	AAA-DW-115A-14	Room 115	9:59	Initial	Bubbler	250mL	
15	AAA-DW-115B-15	Room 115	9:59	Initial	Bubbler	250mL low flow	
16	AAA-DW-116A-16	Room 116	10:01	Initial	Bubbler	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD17709

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-248		CLIENT: Long Branch BOE			FACILITY: Amerigo A. Anastasia School		
PO #: 041155		SAMPLER(S): Adam F.		DATE: 4/16/25		ADDRESS: 92 7th Ave, Long Branch, NJ 07740	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
17	AAA-DW-116B-17	Room 116	10:01	Initial	Bubbler	250mL	
18	AAA-WC-HL1-18	Hall	10:02	Initial	Water Cooler	250mL	
19	AAA-DW-120A-19	Room 120		Initial	Bubbler	250mL	<i>No. flow</i>
20	AAA-DW-120B-20	Room 120	10:04	Initial	Bubbler	250mL	
21	AAA-DW-119A-21	Room 119	10:05	Initial	Bubbler	250mL	
22	AAA-DW-119B-22	Room 119	10:06	Initial	Bubbler	250mL	
23	AAA-DW-122A-23	Room 122	10:08	Initial	Bubbler	250mL	
24	AAA-DW-122B-24	Room 122	10:09	Initial	Bubbler	250mL	<i>dark color</i>
25	AAA-DW-121A-25	Room 121	10:10	Initial	Bubbler	250mL	
26	AAA-DW-121B-26	Room 121	10:12	Initial	Bubbler	250mL	
27	AAA-DW-124-27	Room 124	10:13	Initial	Bubbler	250mL	
28	AAA-DW-123-28	Room 123	10:14	Initial	Bubbler	250mL	
29	AAA-WC-MNHL1-29	Main Hall	10:15	Initial	Water Cooler	250mL	
30	AAA-WC-MNHL2-30	Main Hall	10:16	Initial	Water Cooler	250mL	
30A	AAA-WC-MEDIA-30A	Media Center	10:18	Initial	Water Cooler	250mL	
31	AAA-NS-NRSOFF1-31	Nurse Office	10:20	Initial	Sink	250mL	
32	AAA-NS-NRSOFF2-32	Nurse Office	10:21	Initial	Sink	250mL	
33	AAA-DW-212-33	Room 212	10:22	Initial	Bubbler	250mL	
34	AAA-DW-210-34	Room 210	10:23	Initial	Bubbler	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD17709

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-248		CLIENT: Long Branch BOE			FACILITY: Amerigo A. Anastasia School		
PO #: 041155		SAMPLER(S): Adam F.		DATE: 4/16/25		ADDRESS: 92 7th Ave, Long Branch, NJ 07740	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
35	AAA-WC-HLWY2-35	Hallway	10:25	Initial	Water Cooler	250mL	
36	AAA-DW-214-36	Room 214	10:27	Initial	Bubbler	250mL	
37	AAA-DW-213-37	Room 213	10:28	Initial	Bubbler	250mL	
38	AAA-DW-216-38	Room 216	10:29	Initial	Bubbler	250mL	
39	AAA-DW-215-39	Room 215	10:31	Initial	Bubbler	250mL	
40	AAA-WC-HLWY2A-40	Hallway	10:33	Initial	Water Cooler	250mL	
41	AAA-DW-220-41	Room 220	10:35	Initial	Bubbler	250mL	
42	AAA-DW-219-42	Room 219	10:36	Initial	Bubbler	250mL	
43	AAA-DW-222-43	Room 222	10:37	Initial	Bubbler	250mL	
44	AAA-DW-221-44	Room 221	10:39	Initial	Bubbler	250mL	
45	AAA-DW-224-45	Room 224	10:40	Initial	Bubbler	250mL	
46	AAA-DW-223-46	Room 223	10:41	Initial	Bubbler	250mL	
47	AAA-TS-STF2-47	Teachers Room	10:42	Initial	Teaches Lounge	250mL	
48	AAA-WC-HLWY-48	Hallway	10:44	Initial	Water Cooler	250mL low flow	
49	AAA-DW-310-49	Room 310	10:45	Initial	Bubbler	250mL	
50	AAA-DW-312-50	Room 312	10:46	Initial	Bubbler	250mL	
51	AAA-DW-314-51	Room 314	10:47	Initial	Bubbler	250mL	
52	AAA-DW-313-52	Room 313	10:49	Initial	Bubbler	250mL	
53	AAADW-316-53	Room 316	10:50	Initial	Bubbler	250mL	



1253 North Church Street, Moorestown, NJ 08057
856-840-8800 Fax 856-840-8815

AD17709

LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY

PROJECT #: 25-248		CLIENT: Long Branch BOE			FACILITY: Amerigo A. Anastasia School		
PO #: 041155		SAMPLER(S): Adam F.		DATE: 4/16/25		ADDRESS: 92 7th Ave, Long Branch, NJ 07740	
Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...	
54	AAA-DW-315-54	Room 315	10:52	Initial	Bubbler	250mL	
55	AAA-WC-HLWY3A-55	Hallway	10:53	Initial	Water Cooler	250mL	
56	AAA-DW-319-56	Room 319	10:55	Initial	Bubbler	250mL	
57	AAA-DW-320-57	Room 320	10:56	Initial	Bubbler	250mL	
58	AAA-DW-321-58	Room 321	10:57	Initial	Bubbler	250mL	
59	AAA-DW-322-59	Room 322	10:58	Initial	Bubbler	250mL	
60	AAA-DW-323-60	Room 323	11:00	Initial	Bubbler	250mL	
61	AAA-DW-324-61	Room 324	11:02	Initial	Bubbler	250mL	
62	AAA-TS-STF3-62	3rd floor Storage	11:04	Initial	Sink	250mL	
FB	Field Blank					250mL	
63	AAA-APR-BF-4A	All purpose room	11:06			250mL	
64	AAA-FP-KA-5A	Kitchen	11:08	Initial	sink	250mL	